

Certificate

No. c7220b-22

Customer:

TKM GmbH
Schlossstraße 123
41238 Mönchengladbach, Germany

Class Ea**Test sample(s):**

data cable:

TKM Horizontal Cable – Brand: TKM 1000 – S/FTP – 4X2X AWG22 – Cat. 7A

Part no.: 1111700-3 (B2ca)
1111700-4 (Cca)
1111700-5 (Dca)
1111700-6 (Eca)

connecting hardware:

KSM – Keystone Modul – Cat. 6A – STP – HD – AWG22-24

Part no.: 467768212

Applied standard(s):

DIN EN 50173-1 (2018-10)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

2 Connector Permanent Link, Copper, Class Ea

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **R7220b-22** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 11.02.2022



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



Test laboratory accredited by DAkkS in accordance with DIN EN ISO/IEC 17025:2018.
The accreditation is valid for the test methods listed in certificate D-PL-17559-01-00.

GHMT AG

In der Kolling 320
66450 Bexbach / Germany

P.O. box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**